

KCECC: HERITAGE HALL FIRE ALARM SYSTEM, 820 Heritage Drive

(RFP #2023-04)

ADDENDUM

Issued: November 16, 2023

Following the site meeting on November 7, 2023, Kemptville Campus would like to issue the following supplementary information about the Heritage Hall fire alarm system RFP (#2023-04)

1. How does proponent have to integrate the fume hoods (3) in the kitchen to the new fire alarm system?

The wiring in the fume hood equipment in the kitchen and servatory is in scope and the information below is to assist the proponent in pricing and planning.

The new system is addressable.

- Set of contacts at all three hood locations (pics below)
- For an alarm, an alarm module at the kitchen hood system is required.
- For the relay, a relay module at the gas shut off is required.
- The larger system in main kitchen has a localized alarm presently.

Area Vendors for Range Hood Support

- <https://www.gbfire.com/contact>
- service@totalfire.ca
- [National Fire | Contact Us](#)
- [Home \(rideaufire.com\)](http://rideaufire.com)

Contacts for hood servatory over char grill.



Contacts over the pizza oven

